

Nutech Engineers

Temperature Sensing Devices

143-D Government Industrial Estate, Kandivli West, Mumbai 400 067 ,

Phone : 91-22-8683549 / 91-22-8684580, Fax : 91-22-8674580

email : nutechen@vsnl.com , nutechen@bol.net.in, sales@nutechengineers.com , info@nutechengineers.com

RTD Temperature vs. Resistance Table For European Curve, Alpha = .00385, ITS-90

°C	Ohms	Diff.	°C	Ohms	Diff.	°C	Ohms	Diff.	°C	Ohms	Diff.	°C	Ohms	Diff.
-200	18.52	-	149	40.14	0.42	99	60.67	0.41	49	80.70	0.39	+1	100.39	0.39
199	18.96	0.44	148	40.56	0.42	98	61.07	0.40	48	81.10	0.40	2	100.78	0.39
198	19.39	0.43	147	40.97	0.41	97	61.48	0.41	47	81.50	0.40	3	101.17	0.39
197	19.82	0.43	146	41.39	0.42	96	61.87	0.41	46	81.89	0.39	4	101.56	0.39
196	20.25	0.43	145	41.80	0.41	95	62.29	0.42	45	82.29	0.40	5	101.95	0.39
195	20.68	0.43	144	42.22	0.42	94	62.69	0.40	44	82.69	0.40	6	102.34	0.39
194	21.11	0.43	143	42.64	0.42	93	63.10	0.41	43	83.08	0.39	7	102.73	0.39
193	21.54	0.43	142	43.05	0.41	92	63.50	0.40	42	83.48	0.40	8	103.12	0.39
192	21.97	0.43	141	43.46	0.41	91	63.91	0.41	41	83.88	0.40	9	103.51	0.39
191	22.40	0.43	-140	43.88	0.42	90	64.30	0.39	40	84.27	0.39	10	103.90	0.39
189	23.26	0.43	139	44.29	0.41	89	64.70	0.40	39	84.67	0.40	11	104.29	0.39
188	23.69	0.43	138	44.71	0.42	88	65.11	0.41	38	85.06	0.39	12	104.68	0.39
187	24.12	0.43	137	45.12	0.41	87	65.51	0.40	37	85.46	0.40	13	105.07	0.39
186	24.55	0.43	136	45.53	0.41	86	65.91	0.40	36	85.85	0.39	14	105.46	0.39
185	24.97	0.42	135	45.95	0.42	85	66.31	0.40	35	86.25	0.40	15	105.85	0.39
184	25.39	0.42	134	46.35	0.40	84	66.72	0.41	34	86.64	0.39	16	106.24	0.39
183	25.82	0.43	133	46.76	0.41	83	67.12	0.40	33	87.04	0.40	17	106.63	0.39
182	26.25	0.43	132	47.18	0.42	82	67.52	0.40	32	87.43	0.39	18	107.02	0.39
181	26.67	0.42	131	47.59	0.41	81	67.92	0.40	31	87.83	0.40	19	107.40	0.38
180	27.10	0.43	130	48.00	0.41	-80	68.33	0.41	30	88.22	0.39	20	107.79	0.39
179	27.52	0.42	129	48.41	0.41	79	68.73	0.40	29	88.62	0.40	21	108.18	0.39
178	27.95	0.43	128	48.82	0.41	78	69.13	0.40	28	89.01	0.39	22	108.57	0.39
177	28.37	0.42	127	49.23	0.41	77	69.53	0.40	27	89.40	0.39	23	108.96	0.39
176	28.80	0.43	126	49.64	0.41	76	69.93	0.40	26	89.80	0.40	24	109.35	0.39
175	29.22	0.42	125	50.06	0.42	75	70.33	0.40	25	90.19	0.39	25	109.73	0.38
174	29.65	0.43	124	50.47	0.41	74	70.73	0.40	24	90.59	0.40	26	110.12	0.39
173	30.07	0.42	123	50.88	0.41	73	71.13	0.40	23	90.98	0.39	27	110.51	0.39
172	30.49	0.42	122	51.29	0.41	72	71.53	0.40	22	91.37	0.39	28	110.90	0.39
171	30.92	0.43	121	51.70	0.41	71	71.93	0.40	21	91.77	0.40	29	111.28	0.38
170	31.34	0.42	120	52.11	0.41	70	72.33	0.40	-20	92.16	0.39	30	111.67	0.39
169	31.76	0.42	119	52.52	0.41	69	72.73	0.40	19	92.55	0.39	31	112.06	0.39
168	32.18	0.42	118	52.92	0.40	68	73.13	0.40	18	92.95	0.40	32	112.45	0.39
167	32.61	0.43	117	53.33	0.41	67	73.53	0.40	17	93.34	0.39	33	112.83	0.38
166	33.03	0.42	116	53.74	0.41	66	73.93	0.40	16	93.73	0.39	34	113.22	0.39
165	33.45	0.42	115	54.15	0.41	65	74.33	0.40	15	94.12	0.39	35	113.61	0.39
164	33.86	0.41	114	54.56	0.41	64	74.73	0.40	14	94.52	0.40	36	113.99	0.38
163	34.28	0.42	113	54.97	0.41	63	75.13	0.40	13	94.91	0.39	37	114.38	0.39
162	34.70	0.42	112	55.38	0.41	62	75.53	0.40	12	95.30	0.39	38	114.77	0.39
161	35.12	0.42	111	55.78	0.40	61	75.93	0.40	11	95.69	0.39	39	115.15	0.38
160	35.54	0.42	110	56.19	0.41	60	76.33	0.40	10	96.09	0.40	40	115.54	0.39
159	35.96	0.42	109	56.60	0.41	59	76.73	0.40	9	96.48	0.39	41	115.93	0.39
158	36.38	0.42	108	57.00	0.40	58	77.13	0.40	8	96.87	0.39	42	116.31	0.38
157	36.80	0.42	107	57.41	0.41	57	77.52	0.39	7	97.26	0.39	43	116.70	0.39
156	37.22	0.42	106	57.82	0.41	56	77.92	0.40	6	97.65	0.39	44	117.08	0.38
155	37.63	0.41	105	58.22	0.40	55	78.32	0.40	5	98.04	0.39	45	117.47	0.39
154	38.05	0.42	104	58.63	0.41	54	78.72	0.40	4	98.44	0.40	46	117.85	0.38
153	38.47	0.42	103	59.04	0.41	53	79.11	0.39	3	98.83	0.39	47	118.24	0.39
152	38.89	0.42	102	59.44	0.40	52	79.51	0.40	2	99.22	0.39	48	118.62	0.38
151	39.31	0.42	101	59.85	0.41	51	79.91	0.40	1	99.61	0.39	49	119.01	0.39
150	39.72	0.41	100	60.26	0.41	50	80.31	0.40	±0	100.00	0.39	50	119.40	0.39

Nutech Engineers

Temperature Sensing Devices

143-D Government Industrial Estate, Kandivli West, Mumbai 400 067 ,

Phone : 91-22-8683549 / 91-22-8684580, Fax : 91-22-8674580

email : nutechen@vsnl.com , nutechen@bol.net.in, sales@nutechengineers.com , info@nutechengineers.com

RTD Temperature vs. Resistance Table For European Curve, Alpha = .00385, ITS-90

°C	Ohms	Diff.												
51	119.78	0.38	101	138.89	0.38	151	157.71	0.38	201	176.23	0.37	251	194.47	0.37
52	120.16	0.38	102	139.27	0.38	152	158.08	0.37	202	176.59	0.36	252	194.83	0.36
53	120.55	0.39	103	139.65	0.38	153	158.45	0.37	203	176.96	0.37	253	195.19	0.36
54	120.93	0.38	104	140.03	0.38	154	158.83	0.38	204	177.33	0.37	254	195.55	0.36
55	121.32	0.39	105	140.39	0.36	155	159.20	0.37	205	177.70	0.37	255	195.90	0.35
56	121.70	0.38	106	140.77	0.38	156	159.56	0.36	206	178.06	0.36	256	196.26	0.36
57	122.09	0.39	107	141.15	0.38	157	159.94	0.38	207	178.43	0.37	257	196.62	0.36
58	122.47	0.38	108	141.53	0.38	158	160.31	0.37	208	178.80	0.37	258	196.98	0.36
59	122.86	0.39	109	141.91	0.38	159	160.68	0.37	209	179.16	0.36	259	197.35	0.37
60	123.24	0.38	110	142.29	0.38	160	161.05	0.37	210	179.53	0.37	260	197.71	0.36
61	123.62	0.38	111	142.66	0.37	161	161.43	0.38	211	179.90	0.37	261	198.07	0.36
62	124.01	0.39	112	143.04	0.38	162	161.80	0.37	212	180.26	0.36	262	198.43	0.36
63	124.39	0.38	113	143.42	0.38	163	162.17	0.37	213	180.63	0.37	263	198.79	0.36
64	124.77	0.38	114	143.80	0.38	164	162.54	0.37	214	180.99	0.36	264	199.15	0.36
65	125.17	0.40	115	144.18	0.38	165	162.91	0.37	215	181.36	0.37	265	199.51	0.36
66	125.55	0.38	116	144.56	0.38	166	163.28	0.37	216	181.73	0.37	266	199.87	0.36
67	125.93	0.38	117	144.94	0.38	167	163.66	0.38	217	182.09	0.36	267	200.23	0.36
68	126.32	0.39	118	145.32	0.38	168	164.03	0.37	218	182.46	0.37	268	200.59	0.36
69	126.70	0.38	119	145.69	0.37	169	164.40	0.37	219	182.82	0.36	269	200.95	0.36
70	127.08	0.38	120	146.07	0.38	170	164.77	0.37	220	183.19	0.37	270	201.31	0.36
71	127.46	0.38	121	146.45	0.38	171	165.14	0.37	221	183.55	0.36	271	201.67	0.36
72	127.85	0.39	122	146.82	0.37	172	165.51	0.37	222	183.92	0.37	272	202.03	0.36
73	128.23	0.38	123	147.20	0.38	173	165.88	0.37	223	184.28	0.36	273	202.38	0.35
74	128.61	0.38	124	147.58	0.38	174	166.25	0.37	224	184.65	0.37	274	202.74	0.36
75	128.99	0.38	125	147.95	0.37	175	166.62	0.37	225	185.01	0.36	275	203.10	0.36
76	129.38	0.39	126	148.33	0.38	176	167.00	0.38	226	185.38	0.37	276	203.46	0.36
77	129.76	0.38	127	148.71	0.38	177	167.37	0.37	227	185.74	0.36	277	203.82	0.36
78	130.14	0.38	128	149.08	0.37	178	167.74	0.37	228	186.11	0.37	278	204.18	0.36
79	130.52	0.38	129	149.46	0.38	179	168.11	0.37	229	186.47	0.36	279	204.54	0.36
80	130.90	0.38	130	149.83	0.37	180	168.48	0.37	230	186.84	0.37	280	204.90	0.36
81	131.28	0.38	131	150.21	0.38	181	168.85	0.37	231	187.20	0.36	281	205.25	0.35
82	131.67	0.39	132	150.58	0.37	182	169.22	0.37	232	187.56	0.36	282	205.61	0.36
83	132.05	0.38	133	150.96	0.38	183	169.59	0.37	233	187.93	0.37	283	205.97	0.36
84	132.43	0.38	134	151.34	0.38	184	169.96	0.37	234	188.29	0.36	284	206.33	0.36
85	132.81	0.38	135	151.71	0.37	185	170.33	0.37	235	188.65	0.36	285	206.70	0.37
86	133.19	0.38	136	152.09	0.38	186	170.69	0.36	236	189.02	0.37	286	207.05	0.35
87	133.57	0.38	137	152.46	0.37	187	171.06	0.37	237	189.38	0.36	287	207.41	0.36
88	133.95	0.38	138	152.84	0.38	188	171.43	0.37	238	189.74	0.36	288	207.77	0.36
89	134.33	0.38	139	153.21	0.37	189	171.80	0.37	239	190.11	0.37	289	208.13	0.36
90	134.71	0.38	140	153.58	0.37	190	172.17	0.37	240	190.47	0.36	290	208.48	0.35
91	135.09	0.38	141	153.95	0.37	191	172.54	0.37	241	190.83	0.36	291	208.84	0.36
92	135.47	0.38	142	154.32	0.37	192	172.91	0.37	242	191.20	0.37	292	209.20	0.36
93	135.85	0.38	143	154.71	0.39	193	173.27	0.36	243	191.56	0.36	293	209.55	0.35
94	136.23	0.38	144	155.08	0.37	194	173.64	0.37	244	191.92	0.36	294	209.91	0.36
95	136.61	0.38	145	155.46	0.38	195	174.01	0.37	245	192.28	0.36	295	210.27	0.36
96	136.99	0.38	146	155.83	0.37	196	174.39	0.38	246	192.66	0.38	296	210.62	0.35
97	137.37	0.38	147	156.21	0.38	197	174.75	0.36	247	193.02	0.36	297	210.98	0.36
98	137.75	0.38	148	156.58	0.37	198	175.12	0.37	248	193.38	0.36	298	211.34	0.36
99	138.13	0.38	149	156.96	0.38	199	175.49	0.37	249	193.74	0.36	299	211.69	0.35
100	138.51	0.38	150	157.33	0.37	200	175.86	0.37	250	194.10	0.36	300	212.05	0.36

Nutech Engineers

Temperature Sensing Devices

143-D Government Industrial Estate, Kandivli West, Mumbai 400 067 ,

Phone : 91-22-8683549 / 91-22-8684580, Fax : 91-22-8674580

email : nutechen@vsnl.com , nutechen@bol.net.in, sales@nutechengineers.com , info@nutechengineers.com

RTD Temperature vs. Resistance Table For European Curve, Alpha = .00385, ITS-90

°C	Ohms	Diff.												
301	212.40	0.35	351	230.07	0.35	401	247.43	0.34	451	264.52	0.34	501	281.31	0.33
302	212.76	0.36	352	230.42	0.35	402	247.78	0.35	452	264.86	0.34	502	281.64	0.33
303	213.12	0.36	353	230.77	0.35	403	248.12	0.34	453	265.20	0.34	503	281.97	0.33
304	213.47	0.35	354	231.12	0.35	404	248.46	0.34	454	265.54	0.34	504	282.31	0.34
305	213.83	0.36	355	231.47	0.35	405	248.81	0.35	455	265.87	0.33	505	282.64	0.33
306	214.19	0.36	356	231.81	0.36	406	249.15	0.34	456	266.21	0.34	506	282.97	0.33
307	214.55	0.36	357	232.16	0.35	407	249.50	0.35	457	266.55	0.34	507	283.30	0.33
308	214.90	0.35	358	232.51	0.35	408	249.84	0.34	458	266.89	0.34	508	283.63	0.33
309	215.26	0.36	359	232.86	0.35	409	250.18	0.34	459	267.22	0.33	509	283.97	0.34
310	215.61	0.35	360	233.21	0.35	410	250.53	0.35	460	267.56	0.34	510	284.30	0.33
311	215.97	0.36	361	233.56	0.35	411	250.89	0.34	461	267.90	0.34	511	284.63	0.33
312	216.32	0.35	362	233.91	0.35	412	251.21	0.34	462	268.24	0.34	512	284.96	0.33
313	216.68	0.36	363	234.26	0.35	413	251.55	0.34	463	268.57	0.33	513	285.29	0.33
314	217.03	0.35	364	234.60	0.36	414	251.90	0.35	464	268.91	0.34	514	285.62	0.33
315	217.39	0.36	365	234.95	0.35	415	252.24	0.34	465	269.25	0.34	515	285.95	0.33
316	217.73	0.34	366	235.30	0.35	416	252.59	0.35	466	269.58	0.33	516	286.30	0.35
317	218.08	0.35	367	235.65	0.35	417	252.94	0.35	467	269.92	0.34	517	286.63	0.33
318	218.44	0.36	368	236.00	0.35	418	253.28	0.34	468	270.26	0.34	518	286.96	0.33
319	218.79	0.35	369	236.35	0.35	419	253.62	0.34	469	270.59	0.33	519	287.29	0.33
320	219.15	0.36	370	236.70	0.35	420	253.96	0.34	470	270.93	0.34	520	287.62	0.33
321	219.50	0.35	371	237.05	0.35	421	254.30	0.34	471	271.27	0.34	521	287.95	0.33
322	219.85	0.35	372	237.40	0.35	422	254.65	0.35	472	271.60	0.33	522	288.28	0.33
323	220.21	0.36	373	237.75	0.35	423	254.99	0.34	473	271.94	0.34	523	288.61	0.33
324	220.56	0.35	374	238.09	0.34	424	255.33	0.34	474	272.27	0.33	524	288.94	0.33
325	220.91	0.35	375	238.44	0.35	425	255.67	0.34	475	272.61	0.34	525	289.27	0.33
326	221.27	0.36	376	238.79	0.35	426	256.01	0.34	476	272.95	0.34	526	289.60	0.33
327	221.62	0.35	377	239.14	0.35	427	256.35	0.34	477	273.28	0.33	527	289.93	0.33
328	221.97	0.35	378	239.48	0.34	428	256.70	0.35	478	273.62	0.34	528	290.26	0.33
329	222.32	0.35	379	239.83	0.35	429	257.04	0.34	479	273.95	0.33	529	290.59	0.33
330	222.68	0.36	380	240.18	0.35	430	257.38	0.34	480	274.29	0.34	530	290.92	0.33
331	223.03	0.35	381	240.52	0.34	431	257.72	0.34	481	274.62	0.33	531	291.25	0.33
332	223.38	0.35	382	240.87	0.35	432	258.06	0.34	482	274.96	0.34	532	291.58	0.33
333	223.73	0.35	383	241.22	0.35	433	258.40	0.34	483	275.29	0.33	533	291.90	0.32
334	224.09	0.36	384	241.56	0.34	434	258.74	0.34	484	275.63	0.34	534	292.23	0.33
335	224.45	0.36	385	241.91	0.35	435	259.08	0.34	485	275.96	0.33	535	292.56	0.33
336	224.80	0.35	386	242.25	0.34	436	259.42	0.34	486	276.31	0.34	536	292.90	0.34
337	225.15	0.35	387	242.60	0.35	437	259.76	0.34	487	276.64	0.33	537	293.23	0.33
338	225.50	0.35	388	242.95	0.35	438	260.10	0.34	488	276.97	0.33	538	293.56	0.33
339	225.85	0.35	389	243.29	0.34	439	260.44	0.34	489	277.31	0.34	539	293.89	0.33
340	226.21	0.36	390	243.64	0.35	440	260.78	0.34	490	277.64	0.33	540	294.21	0.32
341	226.56	0.35	391	243.98	0.34	441	261.12	0.34	491	277.98	0.34	541	294.54	0.33
342	226.91	0.35	392	244.33	0.35	442	261.46	0.34	492	278.31	0.33	542	294.87	0.33
343	227.26	0.35	393	244.67	0.34	443	261.80	0.34	493	278.64	0.33	543	295.20	0.33
344	227.61	0.35	394	245.02	0.35	444	262.14	0.34	494	278.98	0.34	544	295.53	0.33
345	227.96	0.35	395	245.36	0.34	445	262.48	0.34	495	279.31	0.33	545	295.85	0.32
346	228.31	0.35	396	245.71	0.35	446	262.83	0.35	496	279.64	0.33	546	296.18	0.33
347	228.66	0.35	397	246.05	0.34	447	263.17	0.34	497	279.98	0.34	547	296.51	0.33
348	229.01	0.35	398	246.40	0.35	448	263.50	0.33	498	280.31	0.33	548	296.84	0.33
349	229.36	0.35	399	246.74	0.34	449	263.84	0.34	499	280.64	0.33	549	297.16	0.32
350	229.72	0.34	400	247.09	0.35	450	264.18	0.34	500	280.98	0.34	550	297.49	0.33

Nutech Engineers

Temperature Sensing Devices

143-D Government Industrial Estate, Kandivli West, Mumbai 400 067 ,

Phone : 91-22-8683549 / 91-22-8684580, Fax : 91-22-8674580

email : nutechen@vsnl.com , nutechen@bol.net.in, sales@nutechengineers.com , info@nutechengineers.com

RTD Temperature vs. Resistance Table For European Curve, Alpha = .00385, ITS-90

°C	Ohms	Diff.												
551	297.82	0.33	601	314.04	0.33	651	329.95	0.31	701	345.59	0.31	751	360.94	0.30
552	298.14	0.32	602	314.36	0.32	652	330.27	0.32	702	345.90	0.31	752	361.24	0.30
553	298.47	0.33	603	314.68	0.32	653	330.58	0.31	703	346.21	0.31	753	361.55	0.31
554	298.80	0.33	604	315.00	0.32	654	330.90	0.32	704	346.52	0.31	754	361.85	0.30
555	299.12	0.32	605	315.32	0.32	655	331.21	0.31	705	346.83	0.31	755	362.15	0.30
556	299.45	0.33	606	315.64	0.32	656	331.53	0.32	706	346.15	0.32	756	362.46	0.31
557	299.78	0.33	607	315.96	0.32	657	331.84	0.31	707	347.46	0.31	757	362.76	0.30
558	300.10	0.32	608	316.28	0.32	658	332.16	0.32	708	347.76	0.30	758	363.06	0.30
559	300.43	0.33	609	316.60	0.32	659	332.47	0.31	709	348.07	0.31	759	363.36	0.30
560	300.75	0.32	610	316.92	0.32	660	332.79	0.32	710	348.38	0.31	760	363.67	0.31
561	301.08	0.33	611	317.24	0.32	661	333.10	0.31	711	348.69	0.31	761	363.97	0.30
562	301.41	0.33	612	317.56	0.32	662	333.41	0.31	712	349.00	0.31	762	364.27	0.30
563	301.73	0.32	613	317.88	0.32	663	333.73	0.32	713	349.31	0.31	763	364.57	0.30
564	302.06	0.33	614	318.20	0.32	664	334.04	0.31	714	349.61	0.30	764	364.88	0.31
565	302.38	0.32	615	318.52	0.32	665	334.36	0.32	715	349.92	0.31	765	365.18	0.30
566	302.71	0.33	616	318.85	0.33	666	334.68	0.32	716	350.23	0.31	766	365.49	0.31
567	303.03	0.32	617	319.17	0.32	667	334.99	0.31	717	350.54	0.31	767	365.79	0.30
568	303.36	0.33	618	319.49	0.32	668	335.31	0.32	718	350.85	0.31	768	366.09	0.30
569	303.68	0.32	619	319.81	0.32	669	335.62	0.31	719	351.15	0.30	769	366.40	0.31
570	304.01	0.33	620	320.12	0.31	670	335.93	0.31	720	351.46	0.31	770	366.70	0.30
571	304.33	0.32	621	320.44	0.32	671	336.25	0.32	721	351.77	0.31	771	367.00	0.30
572	304.66	0.33	622	320.76	0.32	672	336.56	0.31	722	352.07	0.30	772	367.30	0.30
573	304.98	0.32	623	321.08	0.32	673	336.87	0.31	723	352.38	0.31	773	367.60	0.30
574	305.30	0.32	624	321.40	0.32	674	337.18	0.31	724	352.69	0.31	774	367.90	0.30
575	305.63	0.33	625	321.72	0.32	675	337.50	0.32	725	352.99	0.30	775	368.20	0.30
576	305.95	0.32	626	322.03	0.31	676	337.81	0.31	726	353.30	0.31	776	368.50	0.30
577	306.28	0.33	627	322.34	0.31	677	338.12	0.31	727	353.61	0.31	777	368.81	0.31
578	306.60	0.32	628	322.66	0.32	678	338.43	0.31	728	353.91	0.30	778	369.11	0.30
579	306.92	0.32	629	322.98	0.32	679	338.75	0.32	729	354.22	0.31	779	369.41	0.30
580	307.25	0.33	630	323.30	0.32	680	339.06	0.31	730	354.53	0.31	780	369.71	0.30
581	307.57	0.32	631	323.61	0.31	681	339.37	0.31	731	354.83	0.30	781	370.01	0.30
582	307.89	0.32	632	323.93	0.32	682	339.68	0.31	732	355.14	0.31	782	370.31	0.30
583	308.22	0.33	633	324.25	0.32	683	339.99	0.31	733	355.44	0.30	783	370.61	0.30
584	308.54	0.32	634	324.57	0.32	684	340.30	0.31	734	355.75	0.31	784	370.91	0.30
585	308.86	0.32	635	324.88	0.31	685	340.62	0.32	735	356.06	0.31	785	371.21	0.30
586	309.19	0.33	636	325.21	0.33	686	340.94	0.32	736	356.37	0.31	786	371.52	0.31
587	309.51	0.32	637	325.53	0.32	687	341.25	0.31	737	356.68	0.31	787	371.82	0.30
588	309.83	0.32	638	325.85	0.32	688	341.55	0.30	738	356.98	0.30	788	372.12	0.30
589	310.15	0.32	639	326.16	0.31	689	341.87	0.32	739	357.29	0.31	789	372.41	0.29
590	310.48	0.33	640	326.48	0.32	690	342.18	0.31	740	357.59	0.30	790	372.71	0.30
591	310.80	0.32	641	326.79	0.31	691	342.49	0.31	741	357.90	0.31	791	373.01	0.30
592	311.12	0.32	642	327.11	0.32	692	342.80	0.31	742	358.20	0.30	792	373.31	0.30
593	311.45	0.33	643	327.43	0.32	693	343.11	0.31	743	358.51	0.31	793	373.61	0.30
594	311.78	0.33	644	327.74	0.31	694	343.42	0.31	744	358.81	0.30	794	373.91	0.30
595	312.10	0.32	645	328.06	0.32	695	343.73	0.31	745	359.12	0.31	795	374.21	0.30
596	312.43	0.33	646	328.38	0.32	696	344.04	0.31	746	359.42	0.30	796	374.51	0.30
597	312.75	0.32	647	328.69	0.31	697	344.35	0.31	747	359.72	0.30	797	374.80	0.29
598	313.07	0.32	648	329.01	0.32	698	344.66	0.31	748	360.03	0.31	798	374.10	0.30
599	313.39	0.32	649	329.32	0.31	699	344.97	0.31	749	360.33	0.30	799	374.40	0.30
600	313.71	0.32	650	329.64	0.32	700	345.28	0.31	750	360.64	0.31	800	374.70	0.30

Nutech Engineers

Temperature Sensing Devices

143-D Government Industrial Estate, Kandivli West, Mumbai 400 067 ,

Phone : 91-22-8683549 / 91-22-8684580, Fax : 91-22-8674580

email : nutechen@vsnl.com , nutechen@bol.net.in, sales@nutechengineers.com , info@nutechengineers.com

RTD Temperature vs. Resistance Table For European Curve, Alpha = .00385, ITS-90

°C	Ohms	Diff.												
801	376.00	0.30	811	378.98	0.30	821	381.94	0.29	831	384.89	0.29	841	387.84	0.29
802	376.29	0.29	812	379.28	0.30	822	382.24	0.30	832	385.18	0.29	842	388.13	0.29
803	376.59	0.30	813	379.57	0.29	823	382.53	0.29	833	385.48	0.30	843	388.42	0.29
804	376.89	0.30	814	379.87	0.30	824	382.83	0.30	834	385.77	0.29	844	388.72	0.30
805	377.19	0.30	815	380.17	0.30	825	383.12	0.29	835	386.07	0.30	845	389.01	0.29
806	377.49	0.30	816	380.46	0.29	826	383.42	0.30	836	386.37	0.30	846	389.31	0.30
807	377.79	0.30	817	380.76	0.30	827	383.71	0.29	837	386.66	0.29	847	389.61	0.30
808	378.09	0.30	818	381.05	0.29	828	384.01	0.30	838	386.96	0.30	848	389.90	0.29
809	378.39	0.30	819	381.35	0.30	829	384.30	0.29	839	387.25	0.29	849	390.19	0.29
810	378.68	0.29	820	381.65	0.30	830	384.60	0.30	840	387.55	0.30	850	390.48	0.29